



TRENCH SECTIONS

NOTES:

1. THE CONTRACTOR SHALL LOCATE, HORIZONTALLY AND VERTICALLY, ALL UNDERGROUND UTILITIES AND STRUCTURES BEFORE LAYING PIPE WITHIN 200 FEET OF UTILITY CROSSING OR PIPE CONNECTION BY POT HOLING.
2. THE CONTRACTOR SHALL BE RESPONSIBLE FOR MEETING ALL OF THE REQUIREMENTS ESTABLISHED FOR SAFE TRENCHING.
3. PAYMENT FOR TRENCH QUANTITIES SHALL BE FOR ACTUAL AMOUNTS, BUT NOT TO EXCEED MAXIMUM SHOWN FOR IMPROVED TERRAIN.
4. CONTRACTORS MAY USE SLOPING WALLS IN IMPROVED TERRAIN, BUT PAYMENT SHALL BE AS STATED IN NOTE NO. 3.
5. IT SHALL BE THE RESPONSIBILITY OF THE CONTRACTOR TO CONTACT ALL UTILITY COMPANIES TO DETERMINE THE EXACT LOCATION OF ALL UTILITIES AND THEIR SERVICES, AND HE SHALL PROTECT THEM FROM DAMAGE AT ALL TIMES.
6. THE CONTRACTOR SHALL PLACE TEMPORARY AND PERMANENT SURFACES TO CONFORM TO THE REQUIREMENTS OF THE AGENCY ISSUING THE PERMIT.
7. THE CONTRACTOR SHALL RESTORE ALL EXISTING IMPROVEMENTS TO THEIR ORIGINAL CONDITION OR BETTER. ALL COSTS FOR RESTORATION OF IMPROVEMENTS DAMAGED DURING CONSTRUCTION SHALL BE BORNE BY THE CONTRACTOR.
8. TRACER WIRE SHALL BE WRAPPED AROUND ALL NON-METALLIC PIPE.
9. IF A SAW CUT IN THE DIRECTION OF VEHICULAR TRAVEL IS WITHIN A WHEEL PATH, SWDC MAY ORDER ADDITIONAL PAVEMENT REMOVAL SO SAW CUT IS FALLS OUTSIDE A WHEEL PATH.

REV.	DATE	BY	DESCRIPTION
3	12/31/15	TSC	UPDATE PER SWDC
2	9/99	DW	ADDED NOTES
1	10/95	RB	ADDED NOTES



**SUMMIT WATER
DISTRIBUTION COMPANY**

TRENCH DETAILS

STD. DWG. NO.

2